



# Prüfzentrum für Bauelemente

## Dipl.-Ing. (FH) Rüdiger Müller

PfB ♦ Lackermannweg 24 ♦ D-83071 Stephanskirchen

Fenster • windows  
Rollläden • shutters  
Türen + Tore • doors  
Fassaden • curtain walling  
Baubeschläge • building hardware

February 27, 2015

### Letter of Result

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A1:2010”

<b>Applicant</b>	Ersaş Alüminyum Veliköy Organize Sanayi Böl. 4.Cad. No:21 Çerkezköy-Tekirdağ-Türkiye		
<b>Type</b>	Double casement sliding window, Aluminum, Double glazing		
<b>System</b>	<b>ES-40 Sliding Series</b>		
<b>Dimension</b>	Total outside dimensions (W x H) Casement (W x H)	max. 2540 mm x 1540 mm max. 1230 mm x 1375 mm	
<b>Results</b>	EN 1026 Air Permeability EN 1027 Water tightness EN 12211 Resistance to wind load	EN 12207 EN 12208 EN 12210	Class <b>4</b> Class <b>3A</b> Class <b>C4/B5</b>

This Letter is not a certificate for CE-marking.

Nedret Sürmeli  
General Manager

**PfB**  
Danışmanlık Özel Eğitim Denetim Yapı Mlz.  
Laboratuvar Hizmetleri Tic. Ltd. Şti  
10045 Sk. No :7 AOSB Cigli / IZMIR  
TEL 0232 328 10 44 FAX 0232 328 10 22  
Cigli V.D. : 729 050 70 72

PfB GmbH & Co. Prüfzentrum für Bauelemente KG  
AG Traunstein HRA 8871  
Lackermannweg 24, 83071 Stephanskirchen  
phG PfB Verwaltungs GmbH  
Geschäftsführer: Matthias Demmel, Rüdiger Müller  
AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0  
Telefax +49 (0) 80 36 / 67 49 47 28  
www.pfb-rosenheim.de  
info@pfb-rosenheim.de

Sparkasse Rosenheim  
Bankleitzahl 711 500 00  
Kontonummer 500 556 741  
Steuer-Nr.156/172/13009  
USt-IdNr. DE245353602



Anerkannte Prüfstelle  
Landesbauordnung  
**BAY 33**  
Notified Body  
**No. 1644**